

## **SURFACE WATER TREATMENT TECHNIQUE**

The Texas Commission on Environmental Quality (TCEQ) sets minimum water quality standards for public drinking water. These standards included enforceable treatment technique requirements for drinking water. Inadequately treated water may contain disease-causing organisms. These organisms included bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. You do not need to use an alternative water supply.

The **CROSBY MUD**, PWS ID **TX1010118**, failed to meet the minimum treatment technique requirements for the month of **OCTOBER 2025**. Specifically, our water system had more than 5% of the combined filter effluent turbidity readings were above 0.3 NTU for the month.

The Crosby MUD has taken the following corrective actions to prevent a recurrence of the violations: Increased backwashing of the filters.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact the Municipal Operations and Consulting Compliance team at (281) 367-5511.

Posted/Delivered on: March 27, 2026